



BSI Standards Publication

Ventilation for buildings — Ductwork — Cleanliness of ventilation systems

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

raising standards worldwide™

National foreword

This British Standard is the UK implementation of EN 15780:2011.

The UK participation in its preparation was entrusted to Technical Committee RHE/2, Ventilation for buildings, heating and hot water services.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© BSI 2011

ISBN 978 0 580 74008 4

ICS 91.140.30

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 November 2011.

Amendments issued since publication

Date	Text affected
------	---------------

EUROPEAN STANDARD

EN 15780

NORME EUROPÉENNE

EUROPÄISCHE NORM

October 2011

ICS 91.140.30

English Version

Ventilation for buildings - Ductwork - Cleanliness of ventilation systems

Ventilation des bâtiments - Réseaux de conduits - Propreté
des systèmes de ventilation

Lüftung von Gebäuden - Luftleitungen - Sauberkeit von
Lüftungsanlagen

This European Standard was approved by CEN on 11 September 2011.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword	4
1 Scope	5
2 Normative references	6
3 Terms and definitions	6
4 Symbols and units	7
5 Criteria for cleanliness and assessment	7
5.1 General	7
5.2 Assessment of the need for cleaning	7
5.3 Design and handing over information	8
5.4 Determination of cleaning interval	8
5.5 Assessment of the result of cleaning	8
6 Methodology	8
6.1 General methodology	8
6.2 Assessment of the need for cleaning	10
6.2.1 General	10
6.2.2 Inspection plan	10
6.2.3 Evaluation methods of dust accumulation	11
6.3 Cleaning plan	11
6.4 Cleaning methods	12
7 Evaluation and reporting	12
7.1 Evaluation of cleaning	12
7.2 Cleaning report	12
Annex A (informative) Cleanliness quality classes	14
A.1 General	14
A.2 Application in general	14
A.3 Assessment frequency recommendation	14
A.4 Cleanliness class quality measurements	15
A.5 Unacceptable fouling – Extract	15
A.6 Acceptable dust accumulation level (new ductwork)	16
A.7 Acceptable post-clean level	16
Annex B (informative) Example of cleaning plan	17
Annex C (informative) Air Handling Units – specific guidance	20
C.1 General	20
C.2 Recommendations for all cleanliness quality classes	20
C.2.1 Casing, including accessibility/access doors	20
C.2.2 Filters	21
C.2.3 Humidifiers	21
C.2.4 Coils	21
C.2.5 Sound attenuators	21
C.2.6 Fan position and cleaning, including fan motors	21
C.2.7 Drainage and prevention of condensation	21
C.3 Units for advanced cleanliness quality class	21
C.4 Inspection aspects	22
Annex D (informative) Filters – Specific guidance	23
Annex E (informative) Humidifiers – Specific guidance	24

Annex F (informative) Ductwork – Specific installation guidance	25
F.1 Acceptable dust accumulation (new ductwork)	25
F.2 Protection, Delivery and Installation (PDI)	25
F.3 Application of cleanliness levels - airtightness	27
Annex G (informative) Terminal devices and units – Specific guidance	28
Annex H (informative) Measurement methods for dust accumulation	29
H.1 Evaluation methods of dust accumulation	29
H.1.1 General	29
H.1.2 Visual inspection	29
H.1.3 Methods of verifying deposited solid dust and micro-organisms	30
H.2 Summary of methods for evaluation of cleanliness	31
Annex I (informative) Preferred vacuum test method	32
I.1 Test equipment	32
I.2 Sampling procedure	32
I.3 Analysis procedure	33
Bibliography	34

Foreword

This document (EN 15780:2011) has been prepared by Technical Committee CEN/TC 156 “Ventilation for buildings”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2012, and conflicting national standards shall be withdrawn at the latest by April 2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

1 Scope

This European Standard applies to both new and existing ventilation and air conditioning systems and specifies the assessment criteria of cleanliness, cleaning procedures of these systems, and the validation of the effectiveness of cleaning applies also to products, which conform to EN 1505, EN 1506, EN 13053, EN 13180 and EN 13403, used in air conditioning and ventilation systems for human occupancy defined in the scope of CEN/TC 156. This European Standard does not apply to installations for industrial processes.

Cleanliness of ventilation systems is considered important for human comfort and health, energy consumption, system service life and for cleanliness of operations or processes carried out in the ventilated area.

Considerations for change of component as an alternative for cleaning (e.g. in case of flexible ducts and air filters) are also included.

This European Standard specifies general requirements and procedures necessary in assessing and maintaining the cleanliness of ducted ventilation, including:

- cleanliness quality classification;
- how to assess the need for cleaning (visual, measurements);
- assessment frequency (general guidance); guidance of system inspections in accordance with EN 15239, and EN 15240 when relevant;
- selection of cleaning method – to be in line with handing over documentation according to EN 12599;
- how to assess the result of cleaning.

This European Standard is a parallel standard to EN 12097, which specifies requirements for dimension, shape and location for access panels for cleaning and service in ductwork systems.

This European Standard is made as an umbrella standard with informative annexes that can be revised, completed and further added in future revisions of this European Standard for specific system types, and products or applications in the system, such as:

- Air Handling Units (AHU);
- filter;
- humidifiers;
- heat recovery units;
- decentralised air treatment units such as fan-coil units, induction units;
- terminal devices;
- kitchen extract equipment.

The main target groups of this European Standard are specifiers of the cleanliness quality classes and cleaning methods primarily system designers who also specify the system of access, building owners, services companies, maintenance companies, end users and consultancy and control companies.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 12599, *Ventilation for buildings — Test procedures and measuring methods for handing over installed ventilation and air conditioning systems*

EN 12792:2003, *Ventilation for buildings — Symbols, terminology and graphical symbols*

EN 14799:2007, *Air filters for general air cleaning — Terminology*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 12792:2003 and EN 14799:2007 and the following apply.

3.1

acceptable cleanliness level

amount of dust or other impurities not to be exceeded, according to the specified measurement method

3.2

acceptable post-clean level

no loose dust is detected visually on the duct surface after cleaning and the system is capable reaching an acceptable cleanliness level according to a defined measurement method

NOTE In case of conflict (e.g. between the building owner and the user), or uncertainty objective methods are needed to assess the cleanliness/dirtiness.

3.3

acceptable dust accumulation level (new ductwork)

acceptable cleanliness level on new ductwork as handed over from builder to user

NOTE In practice this means the quantity of pollution which is deemed acceptable.

3.4

cleanliness

state or level of pollution defined as acceptable according to specification and a particular measurement method

NOTE Cleanliness is not absolute, it is defined by limit values. Dirtiness is the exceeding of such a defined limit value.

3.5

cleanliness quality class

in the scope of this standard there are three levels of cleanliness quality standards to be applied to various buildings and types of system

- A. Low
- B. Medium
- C. High

3.6

visual inspection

subjective method to evaluate cleanliness level of surfaces

4 Symbols and units

For the purpose of this document, the symbols and units given in EN 12792:2003 apply.

5 Criteria for cleanliness and assessment

5.1 General

The key issue is to design, build and maintain the whole ventilation system so that it can be kept clean enough during the whole lifetime of the installation. The following requirements, as well as the methodology described in Clause 5, applies to the ductwork but can be also applied to air handling units (according to EN 13053) and entire systems (see EN 13779:2007, Annex A) Therefore it is necessary to specify the cleanliness quality class from the beginning and include in the specification both design and installation issues and means to maintain a sufficiently clean ventilation system for its whole lifetime. The design and installation issues shall include (as a minimum):

- cleanliness quality class;
- cleanliness criteria and measurement method;
- production of the system components;
- delivery to site;
- site storage;
- installation;
- protection of components after installation;
- handing over the system according to EN 12599

NOTE Annex A presents, as a common classification, three classes of cleanliness, application examples for ductwork, and recommendations for the frequency of regular inspections in accordance with EN 15239.

5.2 Assessment of the need for cleaning

Inspection of functionality and cleanliness of ventilation system is a part of proper maintenance of the ventilation systems. Mostly the inspection of the cleanliness may arise from two purposes:

- to check if ventilation system is dirty and needs to be cleaned (exceeding of a "target level" of cleanliness);
- to evaluate cleanliness after the cleaning work (to check cleaning work).

The assessment methodology is presented in 6.2.

For existing buildings, the inspection shall include a study of the existing documentation and recommendations to complete and update the documents.

5.3 Design and handing over information

In the handing-over documents the cleanliness quality class, cleanliness criteria and measurement methods shall be specified, recommendations for cleaning methods and guidelines for reaching the points to be cleaned shall also be given.

The design information shall give consideration to the expected cleaning method. Where the system has been designed to be cleaned by wet cleaning methods, warning regarding conditions and restrictions of use should be given. For example wet methods are applicable only where ducts are sufficiently moisture-tight, internal surfaces are smooth, and slope and drainage arrangements have been provided so that fluid and contaminant can be evacuated.

A sufficient number of access doors shall be provided in the ductwork. Additionally special care shall be taken regarding obstacles to cleaning such as dampers, sound attenuators etc., which are mounted in the ducts. In many cases additional access doors are needed after or before such obstacle, which then can be cleaned carefully. Requirements for location of and distance between access doors are presented in EN 12097 and EN 13779.

5.4 Determination of cleaning interval

The cleaning interval shall in principle be defined by reference to the cleanliness or dirtiness of the system. Cleanliness or dirtiness shall in the first instance be assessed visually and this may be confirmed by means of measurement – see Annex A.

The inspection interval to determine the need for cleaning may be defined in the system documentation in order to assist with maintenance planning or design considerations related to cleaning methods.

NOTE Further guidance can be found from REHVA and EVHA Guidelines and also from national guidelines, e.g. VDI 6022 or HVCA TR19.

5.5 Assessment of the result of cleaning

Methods for assessment of the need for cleaning can be also applied for assessment of the result of cleaning.

The preferred method of post-clean verification is given in Annex A.

See also 7.1.

6 Methodology


6.1 General methodology

Figure 1 presents a procedure to control and maintain cleanliness of ventilation system. It does not include the design stages or selection and specification of the system, or any of its components.

The system shall be first checked visually, both in assessing the need for cleaning and in verification of the result of cleaning. Objective measurements are needed if the visual inspection results in disagreement or uncertainty about cleanliness or need for cleaning. See Figure 1 for an explanatory flow-chart.

Objective measurements may be defined in advance as part of the cleaning or inspection plan.

NOTE REHVA Guideline and some national guidelines like VDI 6022 and FiSIAQ Guideline give more detailed guidance on product selection and specification from the hygienic point of view.



Key

- 1 control and maintenance of cleanliness of air handling system
- 2 commissioning
- 3 periodic inspection
- 4 visually clean?
- 5 clearly unclean?
- 6 objective measurements
- 7 acceptable cleanliness level
- 8 cleaning
- 9 verification
- 10 documentation
- Y yes
- N no

Figure 1 — Schematic flow chart for procedures to maintain cleanliness of ventilation system

If the components are certified for cleanliness or the cleanliness after production is otherwise verified, and if the cleanliness instructions are properly documented, the commissioning may be reduced to checking the documentation and spot checking of the system cleanliness (compliance with the documentation). See also 6.2.2.

The methods applied for objective measurements and verification need to be consistent so that the result of inspection is acceptable and give reliable grounds for decision making to order cleaning work of the system when needed. Verification after cleaning is needed for quality control of the cleaning work, and to verify the cleaning result.

NOTE 1 Annex H describes the preferred method of objective measurements.

NOTE 2 An example of acceptable levels of cleanliness (or dirtiness) is explained in Annex F.

Objective methods are needed if any guidelines or demands on cleanliness are set in official or in voluntary documents. The methods to evaluate the cleanliness vary, and thus target values given for the cleaning shall be accompanied by a description of the measurement method. Certain rare visible signs like visible microbial growth are enough to reveal the need for cleaning. For systems (consisting dust with less potential health risks) affected by dust the visible signs are not so clear and evaluation of the need by measurement may be needed to find out whether the ventilation system should be cleaned or not. Suspected instances of hazardous dusts such as asbestos and radiological materials need specialist investigation and should be dealt with separately.

6.2 Assessment of the need for cleaning

6.2.1 General

Assessment of the characteristics of the contamination of the system is important in order to define the cleaning method to be used.

System components are considered to be polluted when visual inspection and analytical verification give evidence of unacceptable dust level, microbial or other contamination. Assessment will be carried out through inspection. Dust accumulation, the type of pollutants, such as "bacterial growth should determine the need for cleaning, cleaning methods to be used and the required environmental controls.

Elements to be inspected for cleanliness start from the outdoor air intake and should include at least:

- Air Handling Units (AHU's). AHU's assessment should include all their components and sections: outdoor air intake, any mixing sections fan section, filters, plenums, heating and cooling coils, condensate trays, sound attenuators, heat recovery section, and humidifier section including droplet eliminators;
- supply air ductwork, including all types of terminal devices and terminal units, sound attenuators, duct-mounted heating and cooling coils, dampers and valves;
- extract air ductwork, including all types of components;
- return and recirculation ductwork, including all types of components;
- fresh air intake ductwork.

6.2.2 Inspection plan

The inspection plan consists of the following information:

- review plan and reports, including cleanliness quality class and measurement methods;

- determining which systems will be inspected;
- determining where to inspect and sample (see note);
- choosing equipment and tools.

Additionally, the inspection plan describes the requirements of the specific qualification and experience for inspectors before they are authorised to carry out inspection work. The assessment frequency shall be specified.

NOTE 1 There are two types of inspection, according to EN 15239: pre-inspection including mainly collection of documentation and brief visual look, and full inspection on site.

For new buildings, owner, specifier and builder may agree a particular inspection plan to suit their requirements.

NOTE 2 Recommendations for assessment frequency are given in Annex A. To obtain objective results a representative number of samples from representative parts and sites in the ventilation system should be selected for evaluation of the cleanliness of the whole system. A good rule of thumb for choosing sites or taking samples is to select areas where the dust deposits are obvious, or liable to cause reduced indoor air quality (IAQ). For inspecting and sampling, the ventilation system can be divided in two parts, the ductwork and the rest of the system. Before inspection or sampling, the sites should be selected at random with the aid of the design documents. The sampling sites in the ductwork should be selected from the main duct starting from the AHU, main ducts, and branch ducts. The sampling sites should include straight duct lengths and ducts with changes of direction or terminations. In the rest of the system, filters or humidifiers give usually a good indication of the cleaning needs.

NOTE 3 System cleanliness inspections should also make reference to other parts of the as described in 6.2.1, and with particular reference to critical components such as filters and wet areas.

6.2.3 Evaluation methods of dust accumulation

Different methods to evaluate cleanliness of ventilation systems are available. The simplest methods are based on more or less subjective visual observation of the cleanliness of ventilation system combined with use of some special instrumentation. The advanced techniques are able to give relatively accurate results that are comparable to given limit values.

NOTE The various methods available are discussed in Annex H. In Annex A preferred measurement methods and limit values are given which relate to various cleanliness quality classes, and to post-clean verification of cleanliness.

6.3 Cleaning plan

If, as assessed according to 6.2, cleaning is needed, a cleaning plan shall be provided. The cleaning plan shall include:

- a summary of the assessment including the list of the systems and parts that need to be cleaned;
- detailed time schedule of cleaning;
- cleaning methods to be applied;
- description of how access will be gained to ducts and equipment not visible in the rooms (ducts, air handling units);
- list of components to be removed for cleaning, and components to be replaced (when relevant);
- protection of the rooms in which the cleaning equipment is used;

- how and when the occupants are informed (including protection and safety considerations);
- microbiological considerations when relevant, including considerations for the use of disinfection;
- criteria to assess the need for involvement of a specialist on microbiological issues; technical data, including an estimate of the present level of dust and impurities, and target levels for cleanliness after cleaning; see Annex A;
- evaluation methods for cleanliness after cleaning.

One example of technical cleaning plan is presented in Annex B.

6.4 Cleaning methods

Cleaning methods shall be sufficient to achieve the required level of cleanliness without damage to the system, to building users' health and safety, and to the environment generally.

NOTE Specific guidance about cleaning methods can be found in guidebooks published both nationally and on an EU basis such as those from REVHA and EVHA.

7 Evaluation and reporting

7.1 Evaluation of cleaning

The final evaluation of cleaning shall be made after all parts of the ductwork or system subject to cleaning have been assessed as visually clean.

Objective verification of post-clean cleanliness shall be carried out where necessary or as a result of dispute or uncertainty.

The preferred method and limit value for post-clean verification of cleanliness is given in Annex A. Other methods may be selected voluntarily by agreement of parties to a cleaning contract.

7.2 Cleaning report

A report shall be prepared and signed. The report shall include at least the following details:

Details of the object (building, ventilation system, etc.):

- the address, name, or other unique identifier of the property;
- the owner or manager of the building;
- the date of the inspection, cleaning and evaluation.

List of the documents provided, including documentation of the product certificates and manufacturer's or supplier's instructions, whenever available.

Details of the systems inspected:

- physical descriptions of the systems subject to inspection and cleaning;
- inventory of equipment.

Methods and equipment used for cleaning, and assessment before and after cleaning (visual, measured):

- results of assessment before cleaning;
- scope of cleaning (entire system/ part of system);
- results of assessment after cleaning;
- documentation of the methods and equipment;
- recommendations (inclusive recommended time for next assessment and cleaning).

Annex A (informative)

Cleanliness quality classes

A.1 General

This annex gives a summary of three cleanliness quality classes. It is a key issue to pay attention to cleanliness in design of systems and especially in component selection and specification. It may be modified to take better into account some existing national guidance such as FiSIAQ guideline and VDI 6022. Application examples are presented in A.2, and more specific applications in Annexes C and D.

The following four major contaminants from all components may deteriorate IAQ and should be limited:

- residues of lubricant oils from duct manufacture;
- dust accumulated during manufacture and installation or debris from construction;
- dust accumulated during operation;
- deposited micro-organisms, particularly when toxigenic species are present and conditions are favourable for their survival and growth during storage, installation and operation.

A.2 Application in general

These levels of cleanliness quality class should be generally applied as follows:

Table A.1 — Typical applications of cleanliness quality classes

Quality Class	Typical examples
Low	rooms with only intermittent occupancy e.g. storage rooms, technical rooms
Medium	offices, hotels, restaurants, schools, theatres, residential homes, shopping areas, exhibition buildings, sport buildings, general areas in hospitals and general working areas in industries
High	Laboratories, treatment areas in hospitals high quality offices

A.3 Assessment frequency recommendation

Assessment frequency described on Table A.2 should be considered as the minimum recommendations and the necessity of increasing them will depend on the environment conditions, on the activity and on mechanical and human conditions in both building and its surroundings.

In most cases inspection frequency should be specified rather than cleaning frequency since changing and unknown conditions may alter the actual required cleaning frequency. Inspection should be regular, cleaning subject to inspection

Table A.2 — Recommended inspection intervals according to cleanliness quality class, in months

	AHU	Filters ^a	Humidifiers	Ducts	Terminals
Low	24	12	12	48	48
Medium	12	12	6	24	24
High	12	6	6	12	12

Air handling units equipped with humidification or adiabatic cooling systems, or located in mild and wet weather conditions should be assessed at least twice a year, whatever the use of the building.

^a Filters should be inspected and maintained according to the manufacturer's recommendations, with these intervals as the minimum ones.

A.4 Cleanliness class quality measurements

The preferred measurement method is derived from the Finnish vacuum test method whereby a gravimetric result is achieved – see Annex I for details of the preferred test method.

This method is suitable for circular, flat-oval and rectangular sheet metal duct types.

For internally-lined (or other irregular, porous surface) ductwork, the gel tape method is preferred, and further work is necessary to establish limit values using this method, however voluntary agreements may be made using this method.

To comply with the cleanliness quality classification samples should show results below the limit values given in Table A.3.

NOTE See also REHVA: Cleanliness of Ventilation Systems 2007, Figures 15 and 16 for illustration of visual comparison to measured levels.

Table A.3 — Acceptable cleanliness levels

Cleanliness quality class	Acceptable cleanliness level Supply ductwork	Acceptable cleanliness level Recirculation or secondary air ductwork
Low	< 4,5 g/m ²	< 6,0 g/m ²
Medium	< 3,0 g/m ²	< 4,5 g/m ²
High	< 0,6 g/m ²	< 3,0 g/m ²

A.5 Unacceptable fouling – Extract

For dry dust-affected extract ductwork (where the air is discharged to atmosphere) less stringent limit values are applied.

Extract systems should be cleaned when airflow through the system reduces by 15 % or more.

If such measurement is not practicable, then the gravimetric dust level measurement may be used. An extract duct should be cleaned when the dust level exceeds 9.0 g/m² using the Finnish vacuum test method.

A.6 Acceptable dust accumulation level (new ductwork)

Acceptable dust accumulation (new ductwork) defines acceptable cleanliness levels on new ductwork as handed over from builder to user. In practice this means the quantity of fouling which is deemed acceptable.

Table A.4 — Acceptable dust accumulation levels in new ductwork

Cleanliness quality class	Acceptable dust accumulation level	Acceptable dust accumulation level
	Supply, recirculation or secondary air ductwork	Extract ductwork
Low	< 0,9 g/m ²	< 1,8 g/m ²
Medium	< 0,6 g/m ²	< 1,8 g/m ²
High	< 0,3 g/m ²	< 0,9 g/m ²

A.7 Acceptable post-clean level

After cleaning the ductwork, and other relevant products or applications in the system all surfaces should be visibly clean and capable of meeting the required Acceptable Post-clean Level.

For most normal duct cleaning work, the preferred method of establishing acceptable post-clean level is to use the vacuum test method – see Annex I for technical details. The post-clean level should be less than 0,3 g/m².

NOTE Other criteria may be voluntarily agreed such as chemical standards e.g. absence of chlorides after fire restoration work, freedom from asbestos fibres, microbiological or radiological contaminants.

Annex B (informative)

Example of cleaning plan

This annex presents one example (according to UNE 100012) of a cleaning plan for dry dust. The cleaning plan is needed in case the assessment reveals a need for cleaning. The tasks listed in the right column are always optional, and also other tasks may be included in the cleaning plan.

The plan is not exhaustive and new technologies may be available to ensure acceptable post-clean level.

CLEANING PLAN (example)		
WORK	TARGET	TASKS (examples; the list of tasks is drawn up case by case as the result of assessment)
1 Cleaning of coils	Achieving design air volume and thermal exchange	<ol style="list-style-type: none"> 1 Brushing and vacuum 2 Detergent/solvent application 3 Brushing 4 Rinse with pressurized water 5 Compressed air
2 Drainage/ condensate tray cleaning	Removing the focus of infection and nutrients that support microbial pollution	<ol style="list-style-type: none"> 1 Brushing and vacuum to dry 2 Detergent application - Disinfection product. 3 Brushing 4 Rinse and dry
3 Fan cleaning	Achieving design air volume and a reduction of the dirtiness of the System downstream	<ol style="list-style-type: none"> 1 Brushing and vacuum 2 Detergent/solvent application 3 Brushing 4 Rinse and dry 5 Compressed air For all blades and casing <p>NOTE Designer may need to provide access to fan blades.</p>
4 Panels cleaning	Avoiding airborne particles to go into the ductwork	<p>*Metallic:</p> <ol style="list-style-type: none"> 1 Brushing and vacuum to dry 2 Detergent application- Disinfection product. 3 Brushing 4 Rinse and dry <p>*Lined with porous insulators</p> <ol style="list-style-type: none"> 1 Brushing and vacuum to dry 2 Sealer product application for fibre sealing

<p>5 Anti corrosion treatment</p>	<p>Avoiding corrosion or corrosion increasing</p>	<p>1 Manual brushing 2 Mechanical brushing 3 Vacuum suction of the total oxide dust 4 Anti corrosion product application</p>
<p>6 System disinfection</p>	<p>Reducing microbial colonisation to a defined level Pollution to a defined level</p>	<p>1 Disinfection product spray or gas NOTE Careful risk assessment is necessary to demonstrate the safety of the procedure for workers, system users, environment and the system itself.</p>

AIR CONDITIONING SYSTEMS CLEANING PROTOCOL

WORK	TARGET	TASKS
<p>1 Cleaning of the extract air ducts</p>	<p>Removing dust Always begin from the end of the air duct, if the system is to be re-used during the course of the work</p>	<p>1 If it is not possible to access through existing openings such as access panels and other openings, then install new access panels 2 Direct vacuum extraction, or dislodging by means such as brushing or compressed air in combination with air/dust extraction</p>
<p>2 Cleaning of extract air terminals</p>	<p>Removing dust</p>	<p>1 Disassembly where necessary 2 Brushing and vaccuming 3 Compressed air 4 Detergent/solvent if necessary and 5 Rinse and dry if wet methods used 6 Re-assembly</p>
<p>3 AHU cleaning</p>	<p>Removing dust</p>	<p>1 Apply the air conditioning system cleaning protocol</p>

<p>4 Diffusers cleaning</p>	<p>Removing dust</p>	<p>1 Disassembly where necessary 2 Brushing and vaccuming 3 Compressed air 4 Detergent/solvent if necessary and 5 Rinse and dry if wet methods used 6 Re-assembly</p>
<p>5 Supply air duct cleaning</p> <p>6 Post-clean verification</p>	<p>Removing dust</p> <p>Always begin from the beginning of the air duct, if the system is to be re-used during the course of the work</p> <p>To confirm that expected outcome has been achieved and to record system condition of Cleanliness</p>	<p>1 If it is not possible to access through existing openings such as access panels and other openings, then install new access panels</p> <p>2 Direct vacuum extraction, or dislodging by means such as brushing or compressed air in combination with air/dust extraction</p> <p>Verify that acceptable post-clean level has been achieved</p> <p>1. Visual inspection 2. Vacuum test to confirm measured level</p>

Annex C (informative)

Air Handling Units – specific guidance

C.1 General

In manufacturing and construction, special attention should be paid on the following aspects:

- complete cleaning before shipment;
- during transportation and storage, sealing of the AHU in such a way that contamination is avoided;
- preserve units during installation in such a way that contamination is avoided;
- inspection and cleaning after installation.

The following examples of material, access and installation requirements, based on EN 13053, are for normal (e.g. residential, office) and advanced cleanliness quality classes (e.g. hospitals) applications. For each criterion they can be applied independently of each other.

C.2 Recommendations for all cleanliness quality classes

C.2.1 Casing, including accessibility/access doors

EN 13053:2006, 6.2 gives requirements and recommendations for AHU casing, taking also into account hygiene and cleanliness aspects, including the following aspects:

- construction and materials;
- accessibility to all components for cleaning and maintenance;
- protection of components from the weather.

The ingress of unfiltered air through casing leakage can cause hygiene problems. The following tightness classes are therefore recommended as a minimum (classes according to EN 1886).

Table C.1 — Recommended minimum tightness class

Cleanliness quality class	Recommended minimum tightness class
Low	L3 (Corresponding air tightness class for ductwork according to EN 13779: A)
Medium	L3 (Corresponding air tightness class for ductwork according to EN 13779: A)
High	L2 (Corresponding air tightness class for ductwork according to EN 13779: B)

C.2.2 Filters

The recommendations given in Annex D apply also for filters and filter sections in air handling units.

C.2.3 Humidifiers

The recommendations given in Annex E apply also for humidifiers and humidification sections in air handling units.

C.2.4 Coils

EN 13053:2006, 6.4 gives requirements and recommendations for heating and cooling coils in AHU's, including:

- construction of the coils, including maximum recommended fin depth and minimum distance between fins;
- special requirements for cleanliness of cooling coils that are designed to dehumidify, including location, materials, accessibility etc.

If the inspection reveals a need for cleaning, the coil surfaces are cleaned according to the instructions. If no instructions are available, it is preferred to use dry methods, such as vacuum cleaning or pressurized air. The result of cleaning can be assessed either by visual inspection or, if feasible, checking the coil pressure drop at the operating air flow.

For cooling coil sections, the same requirements for drainage, cleaning, materials and disinfection apply as for humidifiers, see Annex E.

C.2.5 Sound attenuators

See EN 13053:2006, 6.10.

C.2.6 Fan position and cleaning, including fan motors

The position of the fans in the air-handling unit is important so that proper pressure conditions are maintained to avoid any risks of leakage of contaminated air. This is especially important for units where transfer of particles and gases are possible within the heat recovery section.

The fans and fan motors are cleaned by dry methods: brushing, vacuum or compressed air.

C.2.7 Drainage and prevention of condensation

Penetration of rain or snow into the unit should be prevented by protecting the outdoor air openings against rain and snow and having low air speed into outdoor air openings. In cold climates it can be necessary to have a water-tight plenum section between the outdoor opening and the unit (or the first section) which guides the water immediately out of the building and/or is connected to drain.

NOTE Cold bridges in cabinets introduce a risk of condensation on the inner or outer surfaces, depending on which side of the unit is colder. The bridging factor class, as defined in EN 1886:2007, Clause 7, should therefore be selected to take into account the climatic conditions in which the unit is expected to operate.

C.3 Units for advanced cleanliness quality class

EN 13053:2006, Clause 7 gives extended hygiene requirements for air handling units for special applications, including:

- accessibility for cleaning purposes;
- smoothness of surfaces;
- inspection windows and lights;
- drainage and prevention of condensation.

C.4 Inspection aspects

It is recommended to look at filters and filter sections, as well as humidifiers and humidifier sections at the early stage of the system inspection for cleanliness, because the condition of these components is generally a good indicator of need for cleaning. See also Annexes D and E.

Annex D (informative)

Filters – Specific guidance

Filter clogging and/or bad filter efficiency have a negative impact on indoor air quality, and increase energy consumption of the ventilation system. The side wall on the service side of the filter section should be equipped with an inspection door. The width and height of the door should be greater than the external dimensions of the replaceable filter elements. There should be sufficient free space to the side of the access door, and immediately upstream of front access filters, to allow unrestricted access for filter removal and replacement.

The condition of the filters and the filter section is generally a good indicator of need for cleaning, so it is recommended to ensure that filter quality, integrity of fitting and maintenance is assessed at the beginning of the inspection. Filters should be removed for AHU cleaning, preferably also replaced in connection with AHU cleaning. After the AHU cleaning, cleanliness, fitting and function of filters should be checked. See EN 13779 and EN 13053 for further guidance.

Annex E (informative)

Humidifiers – Specific guidance

The cleanliness of humidifiers and associated sections (of AHU or duct) is critical to good hygiene because the ready availability of moisture will strongly encourage microbiological growth. The condition of the humidifiers is a good indicator of need for cleaning, so humidifiers should be checked at an early stage of the inspection may also be started from the humidifiers.

For humidifiers for normal applications, the requirements and recommendations presented in EN 13053:2006, 6.8 apply. These include:

- selection of materials;
- air filtering upstream and downstream;
- limit values for bacteria content;
- water treatment;
- overflow;
- use of disinfectants;
- arrangements to avoid droplet impingement;
- surface finishing of the humidifier casing;
- inspection and maintenance, including recording.

For additional aspects for humidifiers for special applications, EN 13053:2006, 7.5 apply.

Annex F (informative)

Ductwork – Specific installation guidance

F.1 Acceptable dust accumulation (new ductwork)

Acceptable dust accumulation (new ductwork) defines acceptable cleanliness levels on new ductwork as handed over from builder to user. In practice this means the quantity of fouling which is deemed acceptable.

Table F.1 — Acceptable dust accumulation levels in new ductwork

Cleanliness quality class	Acceptable dust accumulation level	Acceptable dust accumulation level
	Supply, recirculation or secondary air ductwork	Extract air ductwork
Low	< 0,9 g/m ²	< 1,8 g/m ²
Medium	< 0,6 g/m ²	< 1,8 g/m ²
High	< 0,3 g/m ²	< 0,9 g/m ²

Construction sites are inevitably dusty workplaces and so there are severe practical difficulties in keeping duct systems clean. If defined levels of cleanliness are required, then it is often necessary to carry out deliberate post-installation cleaning immediately before commissioning, in order to achieve defined, measurable levels of cleanliness.

F.2 Protection, Delivery and Installation (PDI)

Guidance is given below regarding the preparation and protection of ductwork during manufacture and installation with a view to minimising unnecessary contamination of duct systems.

Table F.2 — Recommendations concerning protection, delivery and installation

PDI Level	Factory seal	Protection during transit	Protection during site storage	Site clean	Cap off on site	Post-installation clean
Basic PDI	No	No	No	No	Risers only	No
Intermediate PDI	No	No	Yes	Yes	Yes	Not unless shown to be necessary
Advanced PDI	Yes	Yes	Yes	Yes	Yes	Yes

Basic level

Condition of ducts ex works: Ductwork leaving the premises of the manufacturer may include some or all of the following:

- internal and/or external self-adhesive labels or marking for part(s) identification;
- exposed mastic sealant;
- light zinc oxide coating on the metal surface;
- a light coating of oil on machine formed parts;
- minor protrusions into the airway of rivets;
- screws, bolts and other jointing devices;
- internal insulation and associated fixings;
- discoloration marks from plasma cutting process.

The ductwork is not generally wiped down or specially cleaned at this level unless specified.

Delivery to site: Unless otherwise specified, ductwork delivered from the premises of the manufacturer is not protected.

Installation: Before the installation of individual duct sections they should be inspected to ensure that they are free from all debris but not be wiped or specially cleaned.

Protection of ductwork risers: All risers should be covered to prevent the entry of debris into the duct. In respect of the safety of personnel, full regard should be given to requirements of health and safety at work. Downward facing and horizontal duct openings: These are not covered.

Intermediate level

The intermediate level includes the following requirements in addition to the provisions of the basic level.

Site storage: The area provided for storage should be permanently clean, dry and protected from site dust and this may require a boarded floor and water resistant covering.

Installation: The working area should be clean and dry and protected from the elements. The internal surfaces of the ductwork sections should be wiped to remove excess dust immediately prior to installation. Open ends on complete ductwork and overnight work-in-progress should be sealed. Prior to the installation of air terminal devices, any remaining protective end covers should be removed before installing the terminal device with the damper in closed position.

Advanced level

Advanced level includes the following requirements in addition to the provisions of the intermediate level.

Since the ductwork will be cleaned post-installation many costly and onerous procedures such as capping during transport can be dispensed for most installations.

In some cases further protection methods may be applied by means of voluntary documents.

Production and site delivery: All self-adhesive labels for part identification should be applied to external surfaces only.

Site storage: A clean, dry and dust free environment should be provided for the storage of ductwork prior to installation.

Installation: The working area should be clean, dry and dust free.

Special considerations: The oil-residues may be only mentioned as a recommendation, because at this time no practicable test method for the use in field is available.

An agreement about allowed microbiological colonisation should be separately specified, including realistic verification criteria. For most uses clean installation is normally enough to keep the level of microbiological colonisation negligible.)

F.3 Application of cleanliness levels - airtightness

The airtightness of the ductwork is also important for cleanliness. Leakages in unclean hollow spaces or suspended ceilings can have a big influence to the indoor air quality, especially for the advanced level. The minimum recommended tightness class related to these cleanliness levels can be expressed as follows, corresponding with the technical recommendations of EN 13779:2007, A.8.2,

Table F.3 — Recommended minimum tightness class

Level	Recommended minimum tightness class
Basic	B
Intermediate	C
Advanced	D

Annex G (informative)

Terminal devices and units – Specific guidance

Diffusers and other supply and exhaust air units, as well as fan coil units, induction units, in-line plant such as CAV and VAV boxes, chilled beams and chilled ceilings, should be easy to clean.

Visual inspection is usually sufficient in assessment of need for cleaning and for the result of cleaning, but verification can be carried out using vacuum test methods as for ductwork.


Annex H (informative)

Measurement methods for dust accumulation

H.1 Evaluation methods of dust accumulation

H.1.1 General

Different methods to evaluate cleanliness of ventilation systems are available. The simplest methods are based on more or less subjective visual observation of the cleanliness of ventilation system combined with use of some special instrumentation. More advanced techniques are able to give relatively accurate results that are comparable to given limit values. In Figure H.1 the methods are presented in sequence of the reliability level of their results.



Key

- A reliability
- 1 vacuum sampling on filter, or wiping the dust with a cloth
- 2 gravimetric tape method
- 3 evaluation with optical gel tape
- 4 visual evaluation with reference scale
- 5 visual survey without reference scale

Figure H.1 — The reliability level of the results by different evaluation methods for dust

H.1.2 Visual inspection

Visual inspection method is a basic method to evaluate the cleanliness of ventilation system. Although it is subjective, as such it gives a very good, low-cost and instant estimate of the condition on ventilation system surfaces. It is usually good enough to detect e.g. extreme microbial growth such as slime in water reservoirs, and deposits from major malfunction of filtration, and to reveal lack of maintenance. The visual inspection may be assisted with technical devices such as cameras, endoscopes, and robotic cameras with video capability. In some references, the visual inspection is

made more repeatable by using standardised forms and notebooks that make the inspection more systematic. To make visual inspection more objective, the inspectors should also have experience from many ventilation systems. In clear cases, visual inspection by a trained person is also a useful method to evaluate cleanliness after the cleaning.

For new installations the visual inspection may be aided with a scale based on reference material consisting of photographs of newly installed ductwork for comparison. The scale presents the amount of dust accumulation on the photographs so that the inspector is enabled to give a numeric value for evaluation.

H.1.3 Methods of verifying deposited solid dust and micro-organisms

Most of the methods to verify cleanliness of ventilation systems are based on the measurement of mass of the dust and debris deposited on a known surface area. In the filter sampling method dust is vacuumed on a weighed filter either with or without a filter housing. In the latter method (typically for dirty ducts), the dust attached to the walls of the filter housing may also be included in the sample. Several methods have been developed in order to loosen dust from the surface. Some methods, such as NADCA/HVCA vacuum test rely on the ability of the method to remove dust from the surface to act as a proxy for the ability of the dust to be re-entrained into normal system airflows.

It is also possible to take a sample without vacuuming by using a wiping method with a filter or nonwoven cloth. Solvent may increase the loosening of the dust from the surface, which makes the method very effective for greasy/oily contamination; however careful consideration is necessary to ensure a proper comparison of pre- and post-sampling weight of the wipe and its solvent, and to ensure consistent wiping pressure.

Sticky tape may also be used to collect deposited dust particles from the surface. The tape is weighed before and after collection of the dust and the difference of the mass is used in calculation of the dust density on the surface. The shape and dimensions of the tape restricts the sampling area constant.

On very dusty surfaces, the collection capacity of tape on surfaces with dusty surfaces can be overwhelmed and so is not applicable in those circumstances.

A gel tape method is applicable for verification of the cleanliness of indoor surfaces. The sample is collected on a transparent tape that contains gelatine gel as glue. The transparency of the tape is measured with a special analyser before and after the sampling. The analyser gives a percentage value (%) which is related to the density of dust particles on the gel surface. The optical method with gelatine tapes or with semi-transparent engineering adhesive tapes may be also used to evaluate the cleanliness of air ducts, especially after duct cleaning.

Another method is based on measuring the thickness of the dust deposit. The thickness of dust layer is measured with the aid of a special device which uses an electromagnetic induction sensor. This method is not typically sensitive enough to be used for post-clean verification.

A simple wet film thickness method using a measuring comb is typically used to measure grease/oil deposits in kitchen extract systems.

Microbial contamination is usually determined by the cultivation method which also enables the identification of the genera and species of micro-organisms. Determining the fungal spore and bacteria counts can be done from a dust sample collected using the filter sampling method.

Direct counting of spores or microbial cells with aid of microscopy is usually impossible because of the high density of dust particle with various light reflectance properties in the samples.

H.2 Summary of methods for evaluation of cleanliness

A list of the evaluation methods is expressed in Table H.1.

Table H.1 — Summary of the methods used for evaluation of cleanliness of ventilation systems

Evaluation method		
Visual inspection		
Non-systematic inspection	No scaling for the cleanliness, subjective	
Systematic	Grades for the cleanliness, semi-objective optical and electrical devices may be used to store pictures and video	
Quantitative methods for dust		
Method	Units	Note
Filter sampling	(g/m ²)	most common, repeatable
-NADCA/HVCA vacuum test method		
-Vacuum/brush method		
Cloth wiping	(g/m ²)	effective when used with solvent, care needed for weighing and pressure
Tape sampling	(g/m ²)	suitable for low levels (<~4 g/m ²)
Gel tape sampling	(%)	need special device
Deposit thickness test	(µm)	need special device
Comb method	(µm)	need a simple instrument
Quantitative methods for micro-organisms		
cultivation of dust sample	(CFU/g)	identification of the cultivable species
cultivation of liquid sample	(CFU/ml)	
cultivation of swab sample	(CFU/m ²)	
counting of spores in dust sample	(spores/g)	gives total spore count, needs a specific separation technique
Quantitative analysis of oil residues (usually not performed in the field)		
Filter contact method	mg/m ²	analysis by gas chromatograph or by IR-spectroscopy

Annex I (informative)

Preferred vacuum test method

I.1 Test equipment

- 1) Air pump: A high volume air sampling pump capable of drawing 15 l/min through a cassette containing 37 mm matched weight or pre-weighed filters.
- 2) Filter media: 37 mm mixed cellulose ester (MCE) matched weight or pre-weighed filters (0,8 µm pore size) in three piece cassette.

If pre-weighed filters are used, care has to be taken to dessicate samples at pre-weighing and post-exposure weighing to counter-act possible humidity effects

Other size sampling filters (pore size 0,8 mm) may be used, and care should be taken to ensure that smaller diameter filters (< 37 mm) are not over-loaded, i.e. they are recommended only for post-clean verification.

- 3) Calibration: Air volume rate calibration device that is accurate to $\pm 5\%$ at 15 l/min.
- 4) Template: Approximately 0,4 mm thick, 0,01 m² sampling area, typically 10 cm × 10 cm. Other shapes can be used to suit different sampling locations.

I.2 Sampling procedure

- 1) Inspect visually the surfaces.
- 2) Secure template to surface to be sampled so that it will not shift position during sample collection. The template to lay flat against the surface to be sampled. Check that the surface to be sampled is dry and that the fans are not running when the sampling is being conducted.
- 3) Remove protective plugs from cassette.
- 4) Attach outlet end of cassette to pump tubing. Attach a 5 cm length of suction tube to the inlet side of the cassette.
- 5) Adjust air flow using appropriate calibration device to 15,0 l/min.
- 6) Vacuum the open area of the template by scraping the inlet tube across the entire exposed area. Move the suction tube at a rate not greater than 5 cm/s.
- 7) After the surface has been vacuumed, remove the tubing and replace the plugs in the capsule.
- 8) Mark the cassette (unless pre-marked) with an indelible pen. A code may be used to protect client confidentiality. A log should be kept to correlate the code with other important information such as job site, location in ductwork, date, etc.

- 9) Send the cassette to an independent laboratory for weighing using a precision balance of at least 4-point accuracy.

I.3 Analysis procedure

- 1) In the case of post-clean verification measurement, the filters alone are weighed, i.e. the difference between the two matched weight filters, or the gain in weight on the pre-weighed filter gives the raw result.
- 2) In the case of measurement of probable dirty surfaces, where loose dust is likely to have been captured in the sampling capsule but not impinged on the filter(s), a different analysis methodology is employed as follows:
 - a) The entire cassette is weighed.

METHOD FOR MATCHED WEIGHT FILTERS

- b) The cassette housing is weighed after the filters and loose dust have been removed and put to one side.
- c) The bottom (clean) of the matched weight filters is weighed and the value multiplied by 2.

The total dust collected in the cassette is calculated as: (a-b-c).

METHOD FOR PRE-WEIGHED FILTER

- d) The cassette housing is weighed after the filter and loose dust have been removed and put to one side.
- e) The weight gain on the pre-weighed filter is measured.

The total dust collected in the cassette is calculated as: (a-d+e)

- 3) The laboratory will report results in grams (g) per the sampled area (100 sq.cm). The raw results should be converted into g/m^2 by multiplying by 100, and an assessment offered in general terms to comprise the report to the client.

Bibliography

UNE 100012 Higienizacion de sistemas de climatizacion (Cleaning of ventilation and air conditioning systems.)

FiSIAQ (2008). Classification of Indoor Climate, Construction, and Building Materials 2008. Finnish Society of Indoor Air Quality and Climate, Espoo, Finland.

HVCA (2002). Cleanliness of Ventilation Systems, Guide to good practice. TR/19. Heating and Ventilating Contractors' Association. London, UK.

NADCA (2004). Assessment, Cleaning, & Restoration of HVAC Systems. An Industry Standard Developed by the National Air Duct Cleaning Association, Washington, DC, NADCA, (ACR 2006).

NADCA (2003). HVAC Inspection Manual, Procedures for Assessing the Cleanliness of Commercial HVAC System, Developed by the National Air Duct Cleaners Association, Washington, DC, NADCA.

SNBH (1992). Checking the performance of ventilation systems, The Swedish National Board of Housing, Building and Planning, General Guidelines

VDI 6022-1 (2011). *Ventilation and indoor-air quality - Hygiene requirements for ventilation and air-conditioning systems and units (VDI Ventilation Code of Practice)*

CIBSE TM 26: Hygienic Maintenance of Office Ventilation Ductwork, 2000

EN 1886:2007, *Ventilation for buildings — Air handling units — Mechanical performance*

EVHA (2006a) Guide to Cleaning and Hygienic Management of Ventilation Systems. European Ventilation Hygiene Association. London, UK

EVHA (2006b) Guide to Cleaning and Risk Management of Grease Extract Systems. European Ventilation Hygiene Association. London, UK

Recommendation concerning cleanliness of ductwork in ventilation systems (1999). EUROVENT Recommendation 07, 1999

Recommendation concerning hygiene aspects of air handling units (2000). EUROVENT Recommendation 14, 2000

Criteria for the cleanliness of ventilation systems and components. REHVA Guidebook 8

Hygienic requirements for ventilation and air-conditioning systems and units. REHVA Guidebook 9

EN 1505, *Ventilation for buildings — Sheet metal air ducts and fittings with rectangular cross section — Dimensions*

EN 1506, *Ventilation for buildings — Sheet metal air ducts and fittings with circular cross-section — Dimensions*

EN 12097, *Ventilation for buildings — Ductwork — Requirements for ductwork components to facilitate maintenance of ductwork systems*

EN 13053:2006, *Ventilation for buildings — Air handling units — Rating and performance for units, components and sections*

EN 13180, *Ventilation for buildings — Ductwork — Dimensions and mechanical requirements for flexible ducts*

EN 13403, *Ventilation for buildings — Non-metallic ducts — Ductwork made from insulation ductboards*

EN 13779:2007, *Ventilation for non-residential buildings — Performance requirements for ventilation and room-conditioning systems*

EN 14239, *Ventilation for buildings — Ductwork — Measurement of ductwork surface area*

EN 15239, *Ventilation for buildings — Energy performance of buildings — Guidelines for inspection of ventilation systems*

EN 15240, *Ventilation for buildings — Energy performance of buildings — Guidelines for inspection of air-conditioning systems*

HVCA TR/19 (2002). *Cleanliness of Ventilation Systems, Guide to good practice*. Heating and Ventilating Contractors' Association. London, UK

British Standards Institution (BSI)

BSI is the independent national body responsible for preparing British Standards and other standards-related publications, information and services.

It presents the UK view on standards in Europe and at the international level.

It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover.

Tel: +44 (0)20 8996 9001 Fax: +44 (0)20 8996 7001

BSI offers Members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Tel: +44 (0)20 8996 7669 Fax: +44 (0)20 8996 7001

Email: plus@bsigroup.com

Buying standards

You may buy PDF and hard copy versions of standards directly using a credit card from the BSI Shop on the website www.bsigroup.com/shop. In addition all orders for BSI, international and foreign standards publications can be addressed to BSI Customer Services.

Tel: +44 (0)20 8996 9001 Fax: +44 (0)20 8996 7001

Email: orders@bsigroup.com

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

Tel +44 (0)20 8996 9001

Fax +44 (0)20 8996 7001

www.bsigroup.com/standards

raising standards worldwide™

Information on standards

BSI provides a wide range of information on national, European and international standards through its Knowledge Centre.

Tel: +44 (0)20 8996 7004 Fax: +44 (0)20 8996 7005

Email: knowledgecentre@bsigroup.com

Various BSI electronic information services are also available which give details on all its products and services.

Tel: +44 (0)20 8996 7111 Fax: +44 (0)20 8996 7048

Email: info@bsigroup.com

BSI Subscribing Members are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration.

Tel: +44 (0)20 8996 7002 Fax: +44 (0)20 8996 7001

Email: membership@bsigroup.com

Information regarding online access to British Standards via British Standards Online can be found at www.bsigroup.com/BSOL

Further information about BSI is available on the BSI website at www.bsigroup.com/standards

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. This does not preclude the free use, in the course of implementing the standard of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained. Details and advice can be obtained from the Copyright & Licensing Manager.

Tel: +44 (0)20 8996 7070

Email: copyright@bsigroup.com

